

DUCT CONFIGURATIONS		
SINGLE LINE	DOUBLE LINE	IDENTIFICATION
		LONG SWEEP 90° ELBOW - RECTANGULAR, ROUND OR OVAL
		SHORT SWEEP 90° ELBOW - RECTANGULAR, ROUND OR OVAL
		45° LATERAL - ROUND TO ROUND OR OVAL TO OVAL
		90° TAKEOFF WITH 45° ELONGATED TEE - ROUND TO ROUND
		90° CONICAL TEE - ROUND TO ROUND OR OVAL TO OVAL
		Y BRANCH - ROUND OR OVAL DUCT
		90° ELBOW - RECTANGULAR DUCT (NO DUCT TURNING VANES)
		90° ELBOW - RECTANGULAR DUCT WITH TURNING VANES
		90° TAKEOFF WITH 45° TAPER - RECTANGULAR TO RECTANGULAR (FOR BRANCH TAKEOFF LONGER THAN 50'-0", USE 15")
		90° RADIUS SPLIT - RECTANGULAR DUCT, PROVIDE SPLITTER DAMPER, X/Y PROPORTIONAL SPLIT
		90° RECTANGULAR SPLIT - RECTANGULAR TO ROUND, PROVIDE SPLITTER DAMPER, X/Y PROPORTIONAL SPLIT
		SPIN-IN WITH BALANCE DAMPER - RECTANGULAR TO ROUND OR RECTANGULAR TO OVAL
GAS SYMBOLS		
SYMBOL	IDENTIFICATION	
	PIPE ABOVE GRADE	
	PIPE BELOW GRADE	
	PIPE UP	
	PIPE DROP	
	PIPE DROP AT TEE	
	PIPE CAP	
	PIPE CONTINUED	
	PIPE TRANSITION	
	TEE	
	SHUT-OFF VALVE	
	GAS PRESSURE REGULATOR	
	BALL VALVE	
	UNION	

SYMBOL	IDENTIFICATION
	DUCT; SINGLE-LINE
	DUCT; DOUBLE-LINE
	45 DEGREE DUCT ELBOW; SINGLE-LINE
	DUCT TRANSITION; SINGLE-LINE
	DUCT TRANSITION; DOUBLE-LINE
	SUPPLY AIR DUCT IN CROSS-SECTION ROUTED UP OR HORIZONTAL MOUNTED SUPPLY AIR DIFFUSER
	RETURN AIR DUCT IN CROSS-SECTION ROUTED UP OR HORIZONTAL MOUNTED RETURN AIR GRILLE
	EXHAUST AIR DUCT IN CROSS-SECTION ROUTED UP OR HORIZONTAL MOUNTED EXHAUST AIR GRILLE
	SUPPLY AIR DUCT IN CROSS-SECTION ROUTED DOWN
	RETURN AIR DUCT IN CROSS-SECTION ROUTED DOWN
	EXHAUST AIR DUCT IN CROSS-SECTION ROUTED DOWN
	ROUND DUCT UP - SUPPLY, RETURN OR EXHAUST
	ROUND DUCT DOWN - SUPPLY, RETURN OR EXHAUST
	VERTICAL MOUNTED SUPPLY AIR DEVICE
	VERTICAL MOUNTED RETURN OR EXHAUST AIR DEVICE
	AIR FROM DEVICE
	AIR TO DEVICE
	BALANCE DAMPER
	MOTORIZED DAMPER
	FIRE DAMPER - HORIZONTAL
	FIRE DAMPER - VERTICAL
	FIRE AND SMOKE DAMPER - HORIZONTAL
	FIRE AND SMOKE DAMPER - VERTICAL
	THERMOSTAT
	TEMPERATURE SENSOR
	CARBON DIOXIDE SENSOR
	POINT OF CONNECTION
	REGISTER NECK SIZE AND MARK (DESIGN CFM)
	CENTERLINE
	SHEET KEYNOTE TAG
	CONTRACTOR EQUIPMENT TAG

ABBREVIATIONS			
ABBRV.	IDENTIFICATION	ABBRV.	IDENTIFICATION
Ø	DIAMETER	ID	INSIDE DIAMETER
&	AND	IN	INCH
@	AT	KW	KILOWATTS
°F	DEGREES FAHRENHEIT	LAT	LEAVING AIR TEMPERATURE
AC	AIR CONDITIONER	LBS	POUNDS
AC/H	AIR CHANGES PER HOUR	LRA	LOCKED ROTOR AMPS
AFF	ABOVE FINISH FLOOR	LVG	LEAVING
AFUE	ANNUAL FUEL UTILIZATION EFFICIENCY	LWT	LEAVING WATER TEMPERATURE
AMP	AMPERE	LWB	LEAVING WET BULB
ARCH	ARCHITECT/ARCHITECTURAL	MAX	MAXIMUM
BDD	BACKDRAFT DAMPER	MBH	1000 BTU PER HOUR
BHP	BRAKE HORSEPOWER	MCA	MINIMUM CIRCUIT AMPACITY
BLDG	BUILDING	MCC	MOTOR CONTROL CENTER
BTUH	BRITISH THERMAL UNITS PER HOUR	MECH	MECHANICAL
CA	COMBUSTION AIR	MFR	MANUFACTURER
CFM	CUBIC FEET PER MINUTE	MIN	MINIMUM
CIRC	CIRCULATING	MOC	MAXIMUM OVERCURRENT PROTECTION
CLG	CEILING	(N)	NEW
CONN	CONNECTION	NC	NORMALLY CLOSED
CONT	CONTINUED, CONTINUATION	NIC	NOT IN CONTRACT
COOL	COOLING	NTS	NOT TO SCALE
COORD	COORDINATE	OA	OUTSIDE AIR
COP	COEFFICIENT OF PERFORMANCE	OBD	OPPOSED BLADE DAMPER
CONST	CONSTRUCTION	OC	ON CENTER
CV	COEFFICIENT OF FLOW	OD	OUTSIDE DIAMETER
dBA	A-WEIGHTED DECIBELS	PD	PRESSURE DROP
DB	DRY BULB	PH	PHASE
DN	DOWN	P/N	PART NUMBER
DSD	DUCT SMOKE DETECTOR	POC	POINT OF CONNECTION
DWGS	DRAWINGS	PSI	POUNDS PER SQUARE INCH
(E)	EXISTING TO REMAIN	P/T	PRESSURE/TEMPERATURE
EA	EXHAUST AIR	QTY	QUANTITY
EAT	ENTERING AIR TEMPERATURE	(R)	RELOCATE EXISTING
EER	ENERGY EFFICIENCY RATIO	RA	RETURN AIR
EF	EXHAUST FAN	REQD	REQUIRED
EFF	EFFICIENCY	RLA	RATED/RUNNING LOAD AMPS
ELEC	ELECTRICAL	RPM	REVOLUTIONS PER MINUTE
EQUIP	EQUIPMENT	SA	SUPPLY AIR
ESP	EXTERNAL STATIC PRESSURE	SC	SENSIBLE COOLING
EWB	ENTERING WET BULB	SEER	SEASONAL ENERGY EFFICIENCY RATIO
EWT	ENTERING WATER TEMPERATURE	SF	SUPPLY FAN OR SQUARE FEET
FD	FIRE DAMPER	SOV	SHUT-OFF VALVE
FSD	FIRE AND SMOKE DAMPER	SOO	SEQUENCE OF OPERATION
FLA	FULL LOAD AMPS	SP	STATIC PRESSURE
FLEX	FLEXIBLE	SPEC	SPECIFICATION
FPM	FEET PER MINUTE	TC	TOTAL (COOLING) CAPACITY
FT	FEET	TEMP	TEMPERATURE
FT HD	FEET HEAD	TSP	TOTAL STATIC PRESSURE
FTR	FLUE THRU ROOF	TSTAT	THERMOSTAT
G	GAS	TYP	TYPICAL
GA	GAUGE	UCD	UNDERCUT DOOR
GPM	GALLONS PER MINUTE	UL	UNDERWRITER'S LABORATORIES
GPR	GAS PRESSURE REGULATOR	UON	UNLESS OTHERWISE NOTED
HP	HORSEPOWER	V	VOLT
HR	HOUR	W/	WITH
HSPF	HEATING SEASONAL PERFORMANCE FACTOR	W	WATTS
HTG	HEATING	WB	WET BULB
HZ	HERTZ	WC	WATER COLUMN
		WT	WEIGHT
		(X)	EXISTING TO BE REMOVED
LEGEND NOTES			
A.	ALL SYMBOLS MAY NOT BE USED IN THIS PROJECT.		
B.	SYMBOLS DO NOT ALWAYS REPRESENT REAL LIFE DIMENSIONS.		
C.	SEE BOOK SPECIFICATIONS FOR ADDITIONAL INFORMATION.		
D.	SEE PLANS FOR DUCT AND PIPE SIZES.		

GENERAL MECHANICAL NOTES

- SCOPE OF WORK:** THIS PROJECT IS NEW CONSTRUCTION. THE PLANS AND SPECIFICATIONS INDICATE THE GENERAL EXTENT OF THE WORK BASED ON OWNER PROVIDED INFORMATION AND LIMITED FIELD VERIFICATION. CONTRACTOR SHALL VISIT SITE, AND REPORT ANY DISCREPANCIES NOTED TO THE ENGINEER PRIOR TO SUBMITTING A BID. CONTRACTOR SHALL BE RESPONSIBLE FOR THE MECHANICAL, PLUMBING, AND ELECTRICAL SYSTEMS NECESSARY TO ACCOMPLISH THE WORK WHETHER OR NOT SPECIFIED AND/OR INDICATED.
- MECHANICAL CONTRACTOR SHALL NOTIFY GENERAL CONTRACTOR TO REPAIR WALL, FLOOR AND CEILING SURFACES AS REQUIRED DUE TO DEMOLITION OR INSTALLATION WORK.
- ALL CONTROL WIRING SHALL BE IN CONDUIT. CONDUIT AND WIRING SHALL BE PROVIDED AND INSTALLED BY THE MECHANICAL CONTRACTOR. PROVIDE AND INSTALL RIGID CONDUIT IN AREAS EXPOSED TO THE ELEMENTS.
- ALL TRANSITIONS IN DUCTWORK SHALL BE MADE AT 15 DEGREES TO EACH FACE MAXIMUM, UNLESS OTHERWISE NOTED OR SPECIFICALLY APPROVED.
- MECHANICAL CONTRACTOR TO REVIEW TRUSS SUBMITTAL PRIOR TO DUCT FABRICATION AND VERIFY TRUSS OPENING SIZES AND DUCT SIZES DO NOT CONFLICT.

LIST OF GOVERNING CODES

THIS WORK SHALL CONFORM TO ALL CURRENT AND ADOPTED LOCAL CODES

- OREGON STRUCTURAL SPECIALTY CODE (OSSC)
- OREGON MECHANICAL SPECIALTY CODE (OMSC)
- OREGON PLUMBING SPECIALTY CODE (OPSC)
- OREGON ENERGY CODE (OEG)
- OREGON FIRE CODE (OFC)

COMMISSIONING MECHANICAL

MECHANICAL SYSTEM COMMISSIONING STATEMENT OF WORK: MECHANICAL SYSTEM COMMISSIONING SHALL BE PROVIDED IN ACCORDANCE WITH THE REQUIREMENTS OF THE 2025 OREGON ENERGY CODE (OEEC). A THIRD PARTY COMMISSIONING AGENT (CXA) WILL BE CONTRACTED BY THE OWNER TO VERIFY SYSTEM PERFORMANCE IN ACCORDANCE WITH OEEC REQUIREMENTS. THE CXA WILL PROVIDE THE COMMISSIONING PLAN AND TEST RESULTS. FUNCTIONAL TESTING WILL BE REQUIRED FOR NEW HVAC SYSTEMS.

MECHANICAL SHEET KEY	
SHEET NUMBER	DESCRIPTION
M001	LEGEND
M002	SCHEDULES
M003	SCHEDULES
M201	FIRST FLOOR - HVAC
M202	MECHANICAL - MEZZANINE
M211	FIRST FLOOR - SECTOR A - HVAC
M212	FIRST FLOOR - SECTOR B - HVAC
M213	MEZZANINE - SECTOR A - HVAC
M214	MEZZANINE - SECTOR B - HVAC
M231	ROOF - HVAC
M301	FIRST FLOOR - HYDRONIC
M302	FIRST FLOOR - SNOWMELT
M311	FIRST FLOOR - SECTOR A - HYDRONIC
M312	FIRST FLOOR - SECTOR B - HYDRONIC
M320	ENLARGED PLANS
M401	FIRST FLOOR - GAS
M501	HOT WATER PIPING DIAGRAMS
M502	CHILLED WATER PIPING DIAGRAMS
M601	CONTROLS
M701	HVAC DETAILS
M702	HVAC & PIPING DETAILS
M703	SNOWMELT DETAILS

FAN COIL UNITS

MARK	SERVING				FAN MOTORS																						ELECTRICAL			WT (LBS)	MAKE & MODEL	NOTES
		CFM	OA	ESP	QTY	BHP	HP	RPM	TC (MBH)	SC (MBH)	EAT DB (F)	LAT DB (F)	EWT (F)	LWT (F)	FLOW (GPM)	WPD (FT. WC)	ROWS	TH (MBH)	EAT DB (F)	LAT DB (F)	EWT (F)	LWT (F)	FLOW (GPM)	WPD (FT. WC)	ROWS	V/PH	MCA	MOCP	SCCR			
FC-101	Classroom 135	1000	450	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-102	Classroom 137	1000	440	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-103	Classroom 140	1000	440	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-104	Classroom 142	1000	440	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-105	Classroom 132	1000	455	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-106	Classroom 130	1000	450	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-107	Classroom 127	1000	450	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-108	Classroom 125	1000	455	0.4	2	0.23	1/3	1008	21.5	15.9	75	57.8	46	60	3.4	0.48	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-109	Office Area	1400	295	0.5	2	0.3	1/3	1235	36.8	24.6	75	56.1	46	55.5	8	1.38	6	33.3	65	89.3	130	100	2.20	0.21	2	208/1	6.75	15	15	193	JCI FNP14	ALL
FC-201	Classroom 157	700	400	0.4	1	0.3	1/3	1204	14.2	10.8	75	58.3	46	60	2.30	1.02	6	20.6	65	95.2	130	100	1.3	0.35	2	208/1	3.75	15	15	166	JCI FNP10	ALL
FC-202	Break 172/Office 201	700	135	0.4	1	0.3	1/3	1204	14.8	11.0	75	58.0	46	59	2.50	1.23	6	14	65	85	130	100	0.90	0.06	2	208/1	3.75	15	15	166	JCI FNP10	ALL
FC-203	Large Conf 208	1100	155	0.4	2	0.3	1/3	1064	21.7	16.6	75	58.6	46	59	3.2	0.43	6	31.7	65	94.4	130	100	2.00	0.20	2	208/1	6.75	15	15	242	JCI FNP16	ALL
FC-204	Entry / Commons	2400	530	0.5	2	0.5	3/4	1075	36.3	36.2	75	58.8	46	61.1	5.10	1.95	6	57.2	65	91.5	130	100	3.90	1.43	2	208/1	16.43	20	20	527	JCI AHD30	ALL
FC-206	Classroom 159	1000	450	0.4	2	0.23	1/3	1008	20.6	15.5	75	58.2	46	61.1	3.1	0.41	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-207	KCC CR 205	1000	450	0.4	2	0.23	1/3	1008	20.6	15.5	75	58.2	46	61.1	3.1	0.41	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-208	KCC CR 204	1000	455	0.4	2	0.23	1/3	1008	20.6	15.5	75	58.2	46	61.1	3.1	0.41	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-209	Classroom 164	1000	455	0.4	2	0.23	1/3	1008	20.6	15.5	75	58.2	46	61.1	3.1	0.41	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL
FC-210	Classroom 161	1000	455	0.4	2	0.23	1/3	1008	20.6	15.5	75	58.2	46	61.1	3.1	0.40	6	29.6	65	95.1	130	100	1.9	0.17	2	208/1	6.75	15	15	254	JCI FNP16	ALL

NOTES:

1. PROVIDE BELIMO ACTUATORS ON ALL CONTROL VALVES. ACTUATORS PROVIDED BY CONTROLS CONTRACTOR AND INSTALLED BY MECHANICAL CONTRACTOR. REFER TO DRAWINGS FOR COIL HANDLING.
2. STAINLESS STEEL DRAIN PAN WITH FACTORY MOUNTED OVERFLOW SWITCH. PROVIDE CONDENSATE PUMP.
3. SEE VENTILATION REQUIREMENTS SCHEDULE FOR OA AIRFLOW REQUIREMENTS. BALANCE OA AIRFLOWS AS NOTED.
4. SEE M701 FOR CONNECTION AND MOUNTING DETAILS.
5. PROVIDE ECM MOTORS
6. PROVIDE WITH 2 WAY CONTROL VALVES ON EACH COIL SEE DETAIL
7. PROVIDE WITH 2" MERV 13 FILTERS

DEDICATED OUTDOOR AIR SYSTEM

MARK	LOCATION	SERVING	SUPPLY FAN					EXHAUST FAN					WINTER (HEATING)						SUMMER (COOLING)						HEATING WATER COIL							CHILLED WATER COIL							ELECTRICAL				WT LBS	MAKE & MODEL
			AIRFLOW CFM	ESP IN WG	MOTOR			AIRFLOW CFM	ESP IN WG	MOTOR			OSA EAT	OSA LAT	EA EAT	EA LAT	TOT EFF. %	OSA EAT	OSA LAT	EA EAT	EA LAT	TOT EFF. %	HEAT MBH	EAT	LAT	EWT	LWT	FLOW GPM	ROWS	WTR PD FT	TOTAL COOL MBH	EAT	LAT	EWT	LWT	FLOW GPM	ROWS	WTR PD FT	V/PH	MCA	MOCp			
					BHP	HP	RPM			CONTROL	BHP	HP																														RPM		
DOAS-1	RR 136 MEZZ	SECTOR A - WEST	2300	2.40	1.27	2	1777	ECM	2300	1.37	0.7	4	1216	10	53	70	28.3	68.7	91	79.3	75	86.6	70.4	88.4	53	92.7	130	110	9	2	0.7	83.2	79.3	56.6	46	50.9	11	6	4.2	208/3	16	20	1875	AAON V3
DOAS-2	RR 160 MEZZ	SECTOR B - NORTH	1290	2.28	0.85	1	2015	ECM	1290	1.24	0.37	1.34	1769	10	53	70	27	71.2	91	79.2	75	86.7	72	43.6	53.3	88.3	130	110	3	2	1.2	47.7	79.2	55.1	46	53.8	8.5	6	5.2	208/3	6	15	1556	AAON V3
DOAS-3	RR 133 MEZZ	SECTOR A - EAST	2215	2.40	1.21	2	1748	ECM	2215	1.34	0.66	4	1195	10	53	70	28.1	69.1	91	79.2	75	86.6	70.7	82.5	54	80	130	110	5.5	2	2.1	82.5	79.2	55.0	46	55.6	12	6	6.2	208/3	16	20	1875	AAON V3
DOAS-4	RR 162 MEZZ	SECTOR B - SOUTH	1830	3.73	1.65	2	2511	ECM	1830	1.5	0.69	1	2222	10	53	70	29.1	67.1	91	79.2	75	86.5	69.4	48	54	80	130	110	4	2	2	62.0	79.2	58.9	46	53.0	12	6	7.9	208/3	9	15	1556	AAON V3

NOTES:

1. SUPPLY FANS AND EXHAUST FANS SHALL BE PROVIDED WITH EC MOTORS.
2. 100% OSA UNIT WITH STATIC PLATE ENERGY RECOVERY.
3. UNIT MOUNTED ON MEZZANINE. REFERENCE STRUCTURAL DOCUMENTS FOR ANCHORAGE REQUIREMENTS.
4. PROVIDE DUCT SMOKE DETECTORS IN SUPPLY AIR AND EXHAUST AIR DUCTWORK. INTERLOCK DETECTORS WITH ELECTRICAL SERVICE TO DE-ENERGIZE UNIT UPON DETECTION OF SMOKE.
5. PROVIDE WITH MOTORIZED DAMPERS ON OA AND EA. ACTUATORS BY CONTROLS CONTRACTOR.

AIR COOLED CHILLER

MARK	EVAPORATOR - OPERATING CONDITION						CONDENSER FANS			COMPRESSORS		ELECTRICAL				EER	IPLV	GLYCOL (%)	REFRIGERANT	REFRIGERANT CHARGE (LBS)	WT (LBS)	MAKE & MODEL	NOTES
	TONS	EWT (F)	LWT (F)	MIN. FLOW (GPM)	DESIGN FLOW (GPM)	WPD (FT. WC)	OADB (F)	QTY	FLA (EACH)	TYPE	QTY	V/PH	MCA	MOCP	SCCR								
CH-1	50	61	46	48	83.86	8	91	2	7.6	SCROLL	4	208/3	235	250	250	11.8	18	30	R454B	66	3503	YORK YLAA0048J17XCB	ALL

NOTES:

1. SOUND PRESSURE: 94 DBA OVERALL. SOUND POWER: 93 DBA OVERALL.
2. PROVIDE COMPRESSOR SOUND BLANKETS.
3. SINGLE POINT POWER CONNECTION AND DISCONNECT. PHASE AND UNDER/OVER VOLTAGE PROTECTION.
4. INSTALL ON XXX (CONCRETE PAD) . SEE X/M701 FOR DETAILS.
5. SEE 1/M502 FOR PIPING DIAGRAM. HEAT TRACE EXTERIOR PIPES.

HOT WATER CONDENSING BOILER

MARK	LOCATION	INPUT [MBH]	HIGH FIRE OUTPUT [MBH]	AFUE [%]	MIN GAS PRESS [IN. WC]	MAX GAS PRESS [IN. WC]	TURNDOWN	MAX GPM	MIN GPM	MAX PD [PSIG]	EWT [°F]	LWT [°F]	MAX PRESS [PSIG]	FLUE DIAM [IN]	AIR INLET [IN]	GAS INLET [IN]	ELEC [V/H/P]	FLA	MANUFACTURER	MODEL	OPER WEIGHT [LBS]	NOTES
B-1	BOILER RM	600	585	97.5	5	14	7:1	105	10	160	110	130	160	4	4	1	120/1	6	LOCHINVAR	FTX600	560	1, 2, 3, 4, 5, 6, 7
B-2	BOILER RM	600	585	97.5	5	14	7:1	105	10	160	110	130	160	4	4	1	120/1	6	LOCHINVAR	FTX600	560	1, 2, 3, 4, 5, 6, 7

NOTES:

1. PROVIDE ONE ANSI CERTIFIED GAS REGULATOR WITH EACH BOILER. CONTRACTOR TO VENT REGULATOR OUTDOORS.
2. PROVIDE MANUFACTURER'S CONDENSATE NEUTRALIZER. ONE PER BOILER.
3. PROVIDE MANUFACTURER'S CONCENTRIC VENT KIT. ONE PER BOILER.
4. PROVIDE 6" CONCRETE SERVICE PAD.
5. PROVIDE WITH BACNET MSTP OPTION FOR INTEGRATION INTO BAS. PROVIDE WITH FLOW SWITCH.
6. PROVIDE HIGH ALTITUDE OPTION IF REQUIRED
7. SEE M501 FOR PIPING DIAGRAM

EXHAUST FANS

MARK	SERVING	CFM	ESP	SONES	MOTOR			FAN RPM	WT LBS	MAKE & MODEL	NOTES
					V/PH	AMPS	WATTS/HP				
KEF-1	KITCHEN GREASE HOOD	2150	1.0	11.5	208/3	4.4	1.5	1073	162	CAPTIVEAIRE DU180HFA	1, 2, 3

NOTES:

1. CONTRACTOR IS RESPONSIBLE FOR PROVIDING A COMPLETE CONTROLS SYSTEM IN ORDER TO ACCOMPLISH THE DESCRIPTION OF CONTROLS DESCRIBED IN SCHEDULE AND IN MAU SEQUENCE OF OPERATION.
2. INTERLOCK HOOD FAN OPERATION W/ MAU-1 FOR BALANCED VENTILATION.
3. REFER TO SHEETS FROM MFR FOR INSTALLATION REQUIREMENTS.

HYDRONIC PUMPS																	
MARK	SERVICE	LOCATION	TYPE	FLOW GPM	HEAD FT	DUTY EFF %	NPSH FT	OPER. RPM	MOTOR						WT LBS	MAKE & MODEL	NOTES
									BHP	HP	RPM	V/PH	CONTROL	TYPE			
CHP-1	CHILLED WATER	BOILER ROOM	VERT. IN-LINE	106	55	58.2	5.8	1893	2.6	3	2000	208/3	VFD	TEFC	185	BG E-80X 2X7B	1,2
CHP-2	CHILLED WATER	BOILER ROOM	VERT. IN-LINE	106	55	58.2	5.8	1893	2.6	3	2000	208/3	VFD	TEFC	185	BG E-80X 2X7B	1,2
BP-1	PRIMARY HW	BOILER ROOM	CIRC. IN-LINE	50	12	56.4	-	2576	-	0.5	-	208/1	ECM	-	35	BG ECOCIRC XL 20-140	2
BP-2	PRIMARY HW	BOILER ROOM	CIRC. IN-LINE	50	12	56.4	-	2576	-	0.5	-	208/1	ECM	-	35	BG ECOCIRC XL 20-140	2
HWP-1	SECONDARY HW	BOILER ROOM	VERT. IN-LINE	116	40	32.8	4.7	1681	1.8	3	2000	208/3	VFD	TEFC	215	BG E-80X 2.5X7B	1,2
HWP-2	SECONDARY HW	BOILER ROOM	VERT. IN-LINE	116	40	62.8	4.7	1681	1.8	3	2000	208/3	VFD	TEFC	215	BG E-80X 2.5X7B	1,2
SP-1	SNOWMELT	BOILER ROOM	CIRC. IN-LINE	17	20	45.8	-	3417	-	0.167	-	115/1	ECM	-	16	BG ECOCIRC XL 36-45	1,2
SP-2	SNOWMELT	BOILER ROOM	CIRC. IN-LINE	17	20	45.8	-	3417	-	0.167	-	115/5	ECM	-	16	BG ECOCIRC XL 36-45	1,2
GENERAL NOTES: A. EFFICIENCY LISTED IS WIRE TO WATER EFFICIENCY. B. CHILLED WATER SYSTEM IS 40% PROPYLENE GLYCOL. HOT WATER SYSTEM IS WATER ONLY. NOTES: 1. PROVIDE WITH INVERTER DUTY MOTOR AND INTEGRATED VFD.																	

ADD 4

SPLIT SYSTEM HEAT PUMPS																
MARK	SERVING	COOL MBH		HEAT MBH	CFM	ELECTRICAL DATA			REFRIGERANT DATA			SEER2	HSPF2	WT LBS	MAKE & MODEL	NOTES
		TC	SC			V/PH	MCA	MOCP	TYPE	LINE LENGTH	CHARGE (LBS)					
HP-01	MDF	30	22	30	-	208/1	19	30	R-32	168 FT	4.081	22	9.7	135.4	LG-KUSAP241A	6
FC-01					389	-	-	-	-	-	-	-	36.6	LG-KNSAP241A	1,2,3,4,5	
HP-02	MDF	14	12	12	-	208/1	12	15	R-32	82 FT	1.81	22.5	10.5	68.8	LG - KSUAB121A	6
FC-02					194	-	-	-	-	-	-	-	19.73	LG - KNUAB121A	1,2,3,4,5	
NOTES:																
1. PROVIDE PROGRAMMABLE THERMOSTAT & CONDENSATE PUMP. ROUTE CONDENSATE TO NEAREST APPROVED RECEPCTACLE.																
2. CONTROLS CONTRACTOR SHALL FURNISH AND INSTALL REMOTE TEMPERATURE SENSOR AND CONNECT TO DDC SYSTEM FOR MONITORING. GENERATE ALARM ON TEMPERATURE RISE ABOVE SETPOINT.																
3. SIZE AND INSTALL REFRIGERANT LINES PER MANUFACTURER'S RECOMMENDATIONS.																
4. PROVIDE WITH MANUFACTURERS FACTORY MOUNTED REFRIGERANT LEAK DETECTOR.																
5. INDOOR UNIT POWERED BY OUTDOOR UNIT.																
6. MOUNT OUTDOOR UNIT ON QSM51200 MINI SPLIT STAND AND ANCHOR TO HOUSEKEEPING PAD.																

ADD 4

Add 4		VENTILATION REQUIREMENTS												
TAG	ROOM	PEOPLE	@	CFM/PERSON	+	AREA	@	CFM/SQ.FT.	/	Ez	=	CFM OSA REQUIRED	CFM OSA PROVIDED	
DOAS-1	CLASSROOM 135	24	@	10.0	+	957.0	@	0.12	/	0.8	=	442.6	450	
	CLASSROOM 137	24	@	10.0	+	951.0	@	0.12	/	0.8	=	439.8	440	
	CLASSROOM 140	24	@	10.0	+	948.0	@	0.12	/	0.8	=	438.5	440	
	CLASSROOM 140	24	@	10.0	+	950.0	@	0.12	/	0.8	=	439.4	440	
	COMMONS	50	@	5.0	+	2,800.0	@	0.06	/	0.8	=	522.5	530	
DOAS-1 TOTAL:												2282.8	2300	
DOAS-2	CLASSROOM 159	24	@	10.0	+	971.0	@	0.12	/	0.8	=	449.1	450	
	CLASSROOM 157	21	@	10.0	+	854.0	@	0.12	/	0.8	=	395.0	400	
	BREAK ROOM 172	10	@	5.0	+	382.0	@	0.06	/	0.8	=	88.3	90	
	SHARED OFFICE 201	4	@	5.0	+	227.0	@	0.06	/	0.8	=	42.0	45	
	LARGE CONFERENCE 209	20	@	5.0	+	394.0	@	0.06	/	0.8	=	152.7	155	
	OFFICE 208	1	@	5.0	+	100.0	@	0.06	/	0.8	=	10.6	15	
	OFFICE 207	1	@	5.0	+	104.0	@	0.06	/	0.8	=	11.1	15	
	HALLWAY 200	0	@	0.0	+	620.0	@	0.06	/	0.8	=	46.5	50	
HALLWAY 105/106	0	@	0.0	+	908.0	@	0.06	/	0.8	=	68.1	70		
DOAS-2 TOTAL:												1263.4	1290	
DOAS-3	CLASSROOM 132	24	@	10.0	+	974.0	@	0.12	/	0.8	=	450.5	455	
	CLASSROOM 130	24	@	10.0	+	972.0	@	0.12	/	0.8	=	449.6	450	
	CLASSROOM 127	24	@	10.0	+	971.0	@	0.12	/	0.8	=	449.1	450	
	CLASSROOM 135	24	@	10.0	+	975.0	@	0.12	/	0.8	=	450.9	455	
	SHARED OFFICE 118	4	@	5.0	+	211.0	@	0.06	/	0.8	=	40.8	45	
	SHARED OFFICE 115	3	@	5.0	+	213.0	@	0.06	/	0.8	=	34.7	35	
	OFFICE 114	1	@	5.0	+	105.0	@	0.06	/	0.8	=	11.2	15	
	OFFICE 113	1	@	5.0	+	104.0	@	0.06	/	0.8	=	11.1	15	
	RECEPTIONS 112	3	@	5.0	+	102.0	@	0.06	/	0.8	=	26.8	30	
	SHARED OFFICE 111	3	@	5.0	+	145.0	@	0.06	/	0.8	=	29.6	30	
	DIRECTORS OFFICE 110	1	@	5.0	+	152.0	@	0.06	/	0.8	=	16.2	20	
	SMALL CONF. 117	6	@	5.0	+	115.0	@	0.06	/	0.8	=	44.6	45	
	OFFICE 119	1	@	5.0	+	120.0	@	0.06	/	0.8	=	12.8	15	
HALLWAY 103	0	@	0.0	+	1,464.0	@	0.06	/	0.8	=	109.8	110		
WORK AREA 120	2	@	5.0	+	419.0	@	0.06	/	0.8	=	44.5	45		
DOAS-3 TOTAL:												2182.0	2215	
DOAS-4	CLASSROOM 161	25	@	10.0	+	982.0	@	0.12	/	0.8	=	454.2	455	
	CLASSROOM 164	24	@	10.0	+	976.0	@	0.12	/	0.8	=	451.4	455	
	LACTATION/QUIET 168	1	@	5.0	+	73.0	@	0.06	/	0.8	=	11.7	15	
	KCC CR 205	24	@	10.0	+	965.0	@	0.12	/	0.8	=	446.3	450	
	KCC CR 206	24	@	10.0	+	952.0	@	0.12	/	0.8	=	440.3	455	
DOAS-4 TOTAL:												1803.9	1830	

ADD 4

MARK	LOCATION	HOT SIDE				COLD SIDE				LMTD	WEIGHT (LBS)	MAKE & MODEL	NOTES
		FLOW (GPM)	INLET TEMP (°F)	OUTLET TEMP (°F)	PRESSURE DROP (PSI)	FLOW (GPM)	INLET TEMP (°F)	OUTLET TEMP (°F)	PRESSURE DROP (PSI)				
HX-1	BOILER	15.8	130	100	1.188	17	85	115	2.282	8.33	182	TACO PF 09-35-1-NH	1
NOTES: 1. FLOOR MOUNTED, SNOW MELT HEAT EXCHANGER WITH 40% PROPYLENE GLYCOL													

HYDRONIC ACCESSORIES						
MARK	DESCRIPTION	SERVING	CONN SIZE	WEIGHT	MAKE AND MODEL	REMARKS
AS-1	AIR SEPARATOR	CHILLED WATER	3	85	TACO 4903AD-125	3 INCH AIR AND DIRT INLINE COALESCING SEPARATOR
BT-1	BUFFER TANK	CHILLED WATER	3	280	TACO BTL0100F	3 INCH 100 GALLON BUFFER TANK. LOW CONNECTIONS
ET-1	EXPANSION TANK	CHILLED WATER	3/4	120	TACO CA90-125	23 GALLON TANK, BLADDER TYPE, FULL ACCEPTANCE
ET-2	EXPANSION TANK	HOT WATER	3/4	120	TACO CA90-125	23 GALLON TANK, BLADDER TYPE, FULL ACCEPTANCE
ET-3	EXPANSION TANK	SNOW MELT	3/4	120	TACO CA90-125	23 GALLON TANK, BLADDER TYPE, FULL ACCEPTANCE
GMU-1	GLYCOL MAKEUP UNIT	CHILLED WATER	-	18	AXIOM DMF300	17 GALLON TANK, 0-45 PSI PRESSURE, DIGITAL CONTROL
GMU-2	GLYCOL MAKEUP UNIT	SNOW MELT	-	18	AXIOM DMF300	17 GALLON TANK, 0-45 PSI PRESSURE, DIGITAL CONTROL
HS-1	HYDRAULIC SEPARATOR	HOT WATER	3	240	TACO 5903P-42	HYDRAULIC SEPARATOR WITH AIR AND DIRT SEPARATION
PF-1	POT FEEDER	CHILLED WATER	3/4	50	AXIOM CBF-5	5 GALLON CHEMICAL BYPASS FEEDER
PF-2	POT FEEDER	HOT WATER	3/4	50	AXIOM CBF-5	5 GALLON CHEMICAL BYPASS FEEDER
NOTES: SEE M501 AND M502 FOR ADDITIONAL DETAILS.						

ADD 4

ADD 4

AIR DISTRIBUTION			
MARK	TYPE	MAKE & MODEL	REMARKS
LS-1	SUPPLY	TITUS FL-10	PRICE LINEAR SLOT, 2 SLOTS, SUPPLY GRILLE, SURFACE MOUNTED, 1" SLOT, 4' LENGTH, FIELD PLENUM
LR-1	RETURN	TITUS FL-10	PRICE LINEAR SLOT, 2 SLOTS, RETURN GRILLE, SURFACE MOUNTED, 1" SLOT, 5' LENGTH, FIELD PLENUM
RG-1	RETURN	TITUS 50F	24X24 EGGCRATE FACE RETURN, MATCH FRAME TO CEILING TYPE, NECK SIZE AS INDICATED
RG-2	RETURN	TITUS 350RL	LOUVERED FACE RETURN, SIZE AS INDICATED
SD-1	SUPPLY	TITUS OMNI	24X24 PLAQUE DIFFUSER, MATCH FRAME TO CEILING TYPE, NECK SIZE AS INDICATED
SD-2	SUPPLY	TITUS 300RL	DOUBLE DEFLECTION LOUVERED FACE SUPPLY, SIZE AS INDICATED
EG-1	EXHAUST	TITUS 50F	24X24 EGGCRATE FACE RETURN, MATCH FRAME TO CEILING TYPE, NECK SIZE AS INDICATED
LV-1	LOUVER	RUSKIN ELF6375DX	LOUVERED SUPPLY, SIZE AS INDICATED
LV-2	LOUVER	RUSKIN ELF6375DX	LOUVERED EXHAUST, SIZE AS INDICATED
NOTES: 1. MAY PROVIDE EQUIVALENT EQUIPMENT FROM NAILOR, PRICE, TUTTLE & BAILEY, GREENHECK.			

ADD 4

ELECTRIC HEATERS							
MARK	SERVING	CFM	KW	AMPS	V/PH	WT LBS	MAKE & MODEL
EH-1	BOILER 149	100	1.5	12.5	120/1	22	BERKO FRA1S12F
EH-2	FIRE RISER 167	100	1.5	12.5	120/1	22	BERKO FRA1S12F
EH-3	VESTIBULE 100	100	1.5	12.5	120/1	22	BERKO FRA1S12F
NOTES: 1. UNITS TO BE WALL MOUNTED AND RECESSED 2. PROVIDE WITH BUILT-IN THERMOSTAT AND SET NO HIGHER THAN 60 DEG F.							



COLEBREIT
ENGINEERING
OREGON CALIFORNIA

BID AND PERMIT SET

KCC CHILDCARE LEARNING
CENTER


PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR
97603

SHEET TITLE:
SCHEDULES

REVISIONS:		
#	DESCRP.	DATE
1	ADD 4	08/29/2025


ISSUE DATE: 08/28/2025

M003



MECHANICAL MEZZANINE
1/16" = 1'-0"

KEYPLAN



BID AND PERMIT SET
KCC CHILDCARE LEARNING CENTER
PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR 97603

SHEET TITLE:
MECHANICAL - MEZZANINE

#	DESCRP.	DATE
1	ADD 4	08/29/2025

ISSUE DATE: 08/28/2025

M202



COLEBREIT
ENGINEERING
OREGON / CALIFORNIA


PVOT
ARCHITECTURE

MECHANICAL SHEET NOTES


1. PROVIDE FLEXIBLE DUCT CONNECTION AT ALL FAN COIL UNIT DUCT CONNECTIONS.
2. PROVIDE 1" DUCT LINER ON DUCTS UPSTREAM AND DOWNSTREAM OF FAN COIL UNITS. 5' MINIMUM FROM POINT OF CONNECTION.
3. PROVIDE ACCESS PANEL OR REMOTE OPERATORS FOR DAMPERS INSTALLED ABOVE INACCESSIBLE CEILINGS.


KEY NOTES

1. PREFABRICATED PERFORATED DUCTWORK THROUGH KITCHEN, BELOW CEILING. COORDINATE FINAL LOCATION IN FIELD WITH LIGHTING AND OTHER TRADES.
2. PREFABRICATED SOLID DUCTWORK ABOVE COOLERS.
3. DRYER VENT UP THRU ROOF. CONFIRM VENT SIZE WITH DRYER SUBMITTAL PRIOR TO INSTALL
4. DUCT CONNECTION TO DOAS UNIT
5. 24"x24" ACCESS HATCH
6. COLD BOX EQUIPMENT BY OTHERS
7. PROVIDE CODE COMPLIANT INSULATION WRAP ON ALL EXPOSED EXTERIOR DUCT WORK
8. PROVIDE SIDE WALL CONCENTRIC VENT KIT FROM MANUFACTURER



1 FIRST FLOOR - SECTOR A - HVAC
M211 1/8" = 1'-0"





MECHANICAL SHEET NOTES


1. PROVIDE FLEXIBLE DUCT CONNECTION AT ALL FAN COIL UNIT DUCT CONNECTIONS.
2. PROVIDE 1" DUCT LINER ON DUCTS UPSTREAM AND DOWNSTREAM OF FAN COIL UNITS. 5' MINIMUM FROM POINT OF CONNECTION.
3. PROVIDE ACCESS PANEL OR REMOTE OPERATORS FOR DAMPERS INSTALLED ABOVE INACCESSIBLE CEILINGS.

KEY NOTES

1. 24"x24" ACCESS HATCH

MECHANICAL MEZZANINE - SECTOR A

1/8" = 1'-0"



COLEBREIT
ENGINEERING
OREGON CALIFORNIA


BID AND PERMIT SET
KCC CHILDCARE LEARNING
CENTER
PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR
97603

SHEET TITLE:
MEZZANINE -
SECTOR A -
HVAC

REVISIONS:		
#	DESCRP.	DATE
1	ADD 4	08/29/2025

ISSUE DATE: 08/28/2025

M213



MECHANICAL SHEET NOTES

1. PROVIDE FLEXIBLE DUCT CONNECTION AT ALL FAN COIL UNIT DUCT CONNECTIONS.
2. PROVIDE 1" DUCT LINER ON DUCTS UPSTREAM AND DOWNSTREAM OF FAN COIL UNITS. 5' MINIMUM FROM POINT OF CONNECTION.
3. PROVIDE ACCESS PANEL OR REMOTE OPERATORS FOR DAMPERS INSTALLED ABOVE INACCESSIBLE CEILINGS.

KEY NOTES

1. 24"x24" ACCESS HATCH

#



COLEBREIT
ENGINEERING
OREGON / CALIFORNIA

BID AND PERMIT SET
KCC CHILDCARE LEARNING
CENTER

PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR
97603

SHEET TITLE:

**MEZZANINE -
SECTOR B -
HVAC**

REVISIONS:

#	DESCRP.	DATE
1	ADD 4	08/29/2025

ISSUE DATE: 08/26/2025


M214

Snow Melt															
Name	Area [ft²]	Circuits	Panel Type	Layer Thickness¹	Total Tube Depth (Center)² [in]	Snow Melting Load [Btu/hr]	Backloss [Btu/hr]	Total Load [Btu/hr]	Unit Load [Btu/(hr·ft²)]	Unit Backloss [Btu/(hr·ft²)]	Insulation	Backloss Mode [Btu/hr]	Surface Temp [°F]	Snow Free Ratio	Confidence
Snow Melt	1,744	9	Snow Melt - Concrete	4.0 in (Slab)	3.4 in	212,965	21,547	234,512	122.1	12.4	5.0 hr ft²·°F/btu	Calculated	33	1 - Clear	95%

¹ Thickness of the layer in which tubing is embedded.
² Total Tube Depth measured from top of snow melting surface to center of tubing.

Circuit Information								
Number	Length [ft]	Tube Size	Spacing [in]	Manifold	Flow [USGPM]	Head Loss [ft water]	Total Load [Btu/hr]	Color
M1.1	240	3/4"	9	Manifold 1	1.67	6.5	23,117	<div></div>
M1.2	286	3/4"	9	Manifold 1	1.94	9.7	26,851	<div></div>
M1.4	261	3/4"	9	Manifold 1	1.78	7.6	24,637	<div></div>
M1.5	277	3/4"	9	Manifold 1	1.91	9.1	26,415	<div></div>
M1.6	283	3/4"	9	Manifold 1	1.96	9.7	27,052	<div></div>
M1.7	292	3/4"	9	Manifold 1	2.02	10.5	27,932	<div></div>
M1.8	249	3/4"	9	Manifold 1	1.69	6.6	23,339	<div></div>
M1.9	303	3/4"	9	Manifold 1	1.98	10.6	27,354	<div></div>
M1.10	292	3/4"	9	Manifold 1	2.01	10.5	27,815	<div></div>

Manifolds								
Name	Manifold Type	# Circuits	Tubing Size	Supply Temp [°F]	Total Flow [USGPM]	Head Loss [ft water]	Total Load [Btu/hr]	Fluid
Manifold 1	Copper, 1-1/2" w/ Shut-Off and Balancing Valves	9	3/4"	111	16.97	11.6	234,512	40% Propylene Glycol





1
M302

LEVEL 1 - SNOWMELT

1/16" = 1'-0"

KEYPLAN






FIRST FLOOR - SECTOR A - HYDRONIC
1/8" = 1'-0"



KEYPLAN



BID AND PERMIT SET

KCC CHILDCARE LEARNING CENTER

PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR 97603

SHEET TITLE:

FIRST FLOOR - SECTOR A - HYDRONIC

REVISIONS:

#	DESCRP.	DATE
1	ADD 4	08/29/2025


ISSUE DATE: 08/26/2025

M311




COLEBREIT
ENGINEERING
OREGON CALIFORNIA

PIVOT
ARCHITECTURE



1 FIRST FLOOR - SECTOR B - HYDRONIC
M312 1/8" = 1'-0"



COLEBREIT
ENGINEERING
OREGON CALIFORNIA


BID AND PERMIT SET
KCC CHILDCARE LEARNING CENTER
PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR 97603

SHEET TITLE:
FIRST FLOOR - SECTOR B - HYDRONIC

REVISIONS:		
#	DESCRP.	DATE
1	ADD 4	08/29/2025

ISSUE DATE: 08/28/2025

M312



1
M320

BOILER ROOM - ENLARGED

3/8" = 1'-0"



COLEBREIT
ENGINEERING
OREGON | CALIFORNIA


BID AND PERMIT SET
KCC CHILDCARE LEARNING CENTER
PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR 97603

SHEET TITLE:
ENLARGED PLANS

REVISIONS:		
#	DESCRP.	DATE
1	ADD 4	08/29/2025

ISSUE DATE: 08/26/2025

M320



3
M401

ENLARGED GAS SECTOR B


1/4" = 1'-0"



1
M501

HOT WATER PIPING DIAGRAM

NTS



COLEBREIT
ENGINEERING
OREGON / CALIFORNIA


BID AND PERMIT SET
KCC CHILDCARE LEARNING CENTER
PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR 97603

SHEET TITLE:
HOT WATER PIPING DIAGRAMS

REVISIONS:		
#	DESCRP.	DATE
1	ADD 4	08/29/2025

ISSUE DATE: 08/28/2025

M501



COLEBREIT
ENGINEERING
OREGON / CALIFORNIA

BID AND PERMIT SET
KCC CHILDCARE LEARNING CENTER
PROJECT #: 20230862
KLAMATH COMMUNITY COLLEGE
7390 S. 6TH ST.
KLAMATH FALLS, OR 97603

SHEET TITLE:

CHILLED WATER PIPING DIAGRAMS

REVISIONS:

#	DESCRP.	DATE
1	ADD 4	08/29/2025

ISSUE DATE: 08/28/2025

M502

DOAS UNITS

- DOAS UNITS - SEQUENCE OF OPERATION & BAS INTERFACE
- DOAS UNITS WILL BE PROVIDED WITH FIELD CONTROLS BY CONTROLS CONTRACTOR TO CONTROL ALL DOAS UNIT COMPONENTS INCLUDING SUPPLY FANS, EXHAUST FANS, ENERGY RECOVERY WHEEL, AND COIL CONTROL VALVES. PROVIDE A COMPLETE SYSTEM TO CONTROL ALL UNIT FUNCTIONS INCLUDING TEMPERATURE CONTROL, SCHEDULING, MONITORING, UNIT SAFETY PROTECTION, AND DIAGNOSTICS. THE SYSTEM SHALL CONSIST OF ALL REQUIRED TEMPERATURE SENSORS, PRESSURE SENSORS, AND CONTROLLERS.
 - THE BUILDING AUTOMATION SYSTEM (BAS) WILL SEND OCCUPIED, UNOCCUPIED, OPTIMAL START, NIGHT HEAT / COOL AND TIMED OVERRIDE COMMANDS. THE BAS WILL SEND DISCHARGE AIR TEMPERATURE SETPOINT AND DUCT STATIC PRESSURE SETPOINT. IF COMMUNICATIONS IS LOST WITH THE BAS, THE CONTROLLER WILL OPERATE IN THE OCCUPIED HEATING MODE USING ITS DEFAULT SETPOINTS.
 - OCCUPIED:**
DURING OCCUPIED PERIODS THE SUPPLY FANS AND EXHAUST FANS WILL RUN CONTINUOUSLY AND THE OUTSIDE AIR DAMPERS AND EXHAUST AIR DAMPERS WILL OPEN TO MAXIMUM POSITIONS. FANS MODULATE SPEED TO MAINTAIN DUCT STATIC PRESSURE AT 0.5" (ADJUSTABLE) BASED ON FEEDBACK FROM DUCT STATIC PRESSURE SENSOR. FINAL DUCT STATIC PRESSURE SETPOINT TO BE DETERMINED DURING TAB. THE ENERGY RECOVERY WHEEL IS ENABLED AND SPEED IS MODULATED VIA VFD AND OUTPUT SIGNAL FROM BAS.
 - COOLING:**
 - WHEN THE UNIT IS IN COOLING MODE, CHILLED WATER CONTROL VALVE MODULATES TO MAINTAIN DISCHARGE AIR TEMPERATURE SETPOINT BASED ON RESET SCHEDULE.
 - RESET SCHEDULE: MINIMUM LEAVING AIR TEMPERATURE OF 55F AT 75F OUTDOOR AIR TEMPERATURE.
 - HEATING:**
 - WHEN THE UNIT IS IN HEATING MODE, HEATING WATER CONTROL VALVE MODULATES TO MAINTAIN DISCHARGE AIR TEMPERATURE SETPOINT BASED ON RESET SCHEDULE.
 - RESET SCHEDULE: MAXIMUM LEAVING AIR TEMPERATURE OF 75F AT 50F OUTDOOR AIR TEMPERATURE.
 - DUCT STATIC PRESSURE:**
 - A DUCT STATIC PRESSURE TRANSDUCER SHALL BE PROVIDED WITH THE SENSOR LOCATED AT APPROXIMATELY TWO-THIRDS OF THE DISTANCE OF THE TOTAL SUPPLY DUCT LENGTH. FAN SPEEDS WILL BE MODULATED TO MAINTAIN STATIC PRESSURE SETPOINT.
 - BUILDING STATIC PRESSURE**
 - A DIFFERENTIAL PRESSURE TRANSDUCER SHALL ACTIVELY MONITOR THE DIFFERENCE IN PRESSURE BETWEEN THE BUILDING (INDOORS) AND OUTDOORS.
 - DEMAND CONTROL VENTILATION**
 - EACH ZONE IS EQUIPPED WITH A CO₂ SENSOR. WHEN ALL ZONES SERVED BY A DOAS UNIT MEASURE CO₂ CONCENTRATIONS BELOW 800 PPM (ADJUSTABLE), THE DOAS SHALL OPERATE AT THE DCV MINIMUM OUTDOOR AIRFLOW. IF ANY ZONE EXCEEDS THE CO₂ THRESHOLD OF 800 PPM (ADJUSTABLE) FOR MORE THAN 5 CONTINUOUS MINUTES, THE DOAS SHALL MODULATE OUTDOOR AIRFLOW USING A PID CONTROL LOOP TO GRADUALLY INCREASE FROM THE DCV MINIMUM TO THE DCV MAXIMUM AIRFLOW. ONCE ALL ZONE CO₂ LEVELS FALL BELOW THE SETPOINT, THE DOAS SHALL MODULATE AIRFLOW BACK DOWN TO THE DCV MINIMUM.
 - FROST CONTROL**
 - THE BAS SHALL MODULATE THE ENERGY WHEEL SPEED VIA VFD TO PREVENT FROST BUILD UP. FROST CONTROL SHALL ENABLE WHEN OAT FALLS BELOW 40°F (ADJ.) AND SHALL REDUCE WHEEL SPEED AS REQUIRED TO MAINTAIN EXHAUST-AIR LEAVING WHEEL TEMPERATURE (EALWT) AT OR ABOVE 34°F (ADJ.). IF EALWT CANNOT BE MAINTAINED AT MINIMUM WHEEL SPEED, THE WHEEL SHALL CYCLE OFF INTERMITTENTLY
 - UNOCCUPIED (NIGHT SETBACK):**
DOAS UNIT IS OFF.
 - SAFETY SHUTDOWN:**
WHEN OCCUPIED, SUPPLY FANS SHALL SHUT DOWN WHENEVER THE RELATED DUCT SMOKE DETECTOR ALARMS, AND WHEN ANY OTHER SMOKE DETECTOR IN THE AREA SERVED BY THE DOAS UNIT ALARMS.
 - FILTER STATUS:**
A DIFFERENTIAL PRESSURE SWITCH WILL MONITOR THE DIFFERENTIAL PRESSURE ACROSS THE FILTER WHEN THE FAN IS RUNNING. IF THE SWITCH CLOSSES DURING NORMAL OPERATION A DIRTY FILTER ALARM WILL BE ANNUNCIATED.
 - ALARMS:**
AT A MINIMUM, PROVIDE UNIT FAILURE, SUPPLY FAN FAILURE, EXHAUST FAN FAILURE, HIGH / LOW SUPPLY AIR TEMPERATURE, HIGH / LOW SUPPLY AIR STATIC PRESSURE, CONDENSATE OVERFLOW, HIGH / LOW STATIC PRESSURE, DIRTY FILTER.
 - UNIT STATUS:**
AT A MINIMUM, PROVIDE STATUS OF UNIT MODE, ENERGY RECOVERY WHEEL, FANS, AND DAMPERS

DOMESTIC HOT WATER

- DOMESTIC HOT WATER - SEQUENCE OF OPERATION & BAS INTERFACE
- LEAD/LAG OPERATION: PROVIDE AUTOMATIC LEAD/LAG CONTROL FOR TWO (2) PUMPS. ONLY ONE (1) PUMP SHALL OPERATE AT A TIME.
 - MONTHLY ALTERNATION: ALTERNATE LEAD PUMP SELECTION MONTHLY TO BALANCE RUN TIMES.
 - FAILURE ALARM & SWITCHOVER: UPON FAILURE OF THE OPERATING PUMP, AUTOMATICALLY SWITCH TO THE STANDBY PUMP AND GENERATE A PUMP FAILURE ALARM AT THE BMS.
 - OCCUPANCY-BASED ENABLE/DISABLE: ENABLE PUMPS BASED ON THE BUILDING OCCUPANCY SCHEDULE; DISABLE WHEN UNOCCUPIED.
 - TEMPERATURE CONTROL: PROVIDE A RETURN WATER TEMPERATURE SENSOR. TURN PUMPS OFF WHEN RETURN TEMPERATURE IS ABOVE THE SETPOINT; ENABLE THEM WHEN RETURN TEMPERATURE DROPS BELOW SETPOINT.
 - RESPONSIBILITIES:
 - BMS CONTRACTOR: FURNISH TEMPERATURE SENSORS, CONTROL RELAYS, AND NECESSARY INTERFACE POINTS. PROVIDE PROGRAMMING FOR LEAD/LAG CONTROL, ALARM, AND SCHEDULING.
 - PLUMBER: INSTALL PUMPS, TEMPERATURE SENSOR WELLS, AND PIPING AS INDICATED.
 - ELECTRICIAN: PROVIDE POWER WIRING, AND IF SPECIFIED, CONDUIT FOR CONTROL WIRING.

SNOW MELT

- SNOW MELT - SEQUENCE OF OPERATION & BAS INTERFACE
- GENERAL: CONTRACTOR SHALL PROVIDE A COMPLETE SYSTEM OF CONTROLS TO ENABLE A FULLY FUNCTIONAL SNOW MELT SYSTEM TO BE CONNECTED TO THE BUILDING AUTOMATION SYSTEM (BAS).
- SNOW MELT PUMPS SHALL BE CONTROLLED BY THE BAS.
 - HEAT EXCHANGER (HX) CONTROL VALVE SHALL BE CONTROLLED BY THE BAS. CONTROL VALVE SHALL BE 100% CLOSED WHENEVER THE ICE/SNOW CONDITION IS CLEARED AND THE OAT IS ABOVE 32 DEG F (ADJ.).
 - UPON A CALL FOR HEAT FROM THE ZONE SLAB SENSOR FROM ICE OR SNOW, CIRCULATION PUMP SHALL BE ENERGIZED AND THE HEATING WATER VALVES SHALL BE MODULATED TO MAINTAIN 120 DEG F (ADJ.) SUPPLY TEMPERATURE TO THE SNOW MELT SYSTEM. THE SUPPLY TEMPERATURE SHALL BE MAINTAINED AND THE PUMP SHALL OPERATE UNTIL 30 MINUTES (ADJ.) PAST THE ICE/SNOW CONDITION BEING CLEARED.

KITCHEN MECHANICAL EQUIPMENT

- KITCHEN MECHANICAL EQUIPMENT - SEQUENCE OF OPERATION & BAS INTERFACE
- GENERAL: MECHANICAL SYSTEM CONSISTS OF TYPE 1 GREASE EXHAUST FAN (KEF), MAKEUP AIR UNIT (MAU), GREASE HOOD, HOOD CONTROL PANEL, DUCT TEMPERATURE SENSOR, AND ROOM TEMPERATURE SENSOR. HOOD CONTROL PANEL AND MAKEUP AIR UNIT CONTROLLER BY CAPTIVEAIRE. SEE FOOD SERVICE DRAWINGS FOR DETAILS, CONTROL SEQUENCE, AND ADDITIONAL REQUIREMENTS. CAPTIVEAIRE CONTROLLERS SHALL BE INTEGRATED TO BAS VIA BACNET.
- KITCHEN HOOD EXHAUST FAN (KEF) SHALL OPERATE ACCORDING TO AUTOMATIC, MANUAL, SCHEDULED, OR FIRE COMMANDS FROM HOOD CONTROL PANEL.
 - MAKEUP AIR UNIT (MAU) SHALL BE INTERLOCKED TO THE KITCHEN HOOD EXHAUST FAN (KEF-01) AND SHALL PROVIDE MAKEUP AIR TO THE HOOD WHEN IN OPERATION. MAKEUP AIR UNIT SHALL ALSO PROVIDE SPACE CONDITIONING.
 - BAS SHALL MONITOR THE STATUS OF KEF AND MAU, AND GENERATE AN ALARM UPON A FAILURE TO RUN CONDITION.

HEATING WATER SYSTEM

- HEATING WATER SYSTEM CONTROL SEQUENCE (B-1, B-2, BP-1, BP-2, HWP-1, HWP-2)
- BOILERS INCORPORATE INTEGRAL TEMPERATURE AND SAFETY CONTROLS. DDC SYSTEM INTERFACES TO BOILER THROUGH BACNET NETWORK. BOILERS AND PUMPS ARE CONTROLLED BY THE BUILDING AUTOMATION SYSTEM (BAS).
 - BOILERS (B-1, B-2)
 - BOILERS SHALL BE ENABLED WHENEVER:
 - A PERCENTAGE OF ZONES CALL FOR HEATING (10%, ADJ.)
 - AND THE OUTSIDE AIR TEMPERATURE IS BELOW 75F (ADJ.)
 - THE BOILER SHALL BE ENABLED A USER ADJUSTABLE TIME AFTER BOILER PUMP STATUS IS PROVEN ON. DELAY ON START SHALL BE ADJUSTABLE.
 - BOILER SHALL NOT BE ENABLED UNTIL FLOW THROUGH BOILER IS PROVEN BY THE FLOW SWITCH AND SAFETY INTERLOCKS ARE PROVEN (LOW WATER, BLOCKED FLUE, HIGH LIMIT, AIRFLOW, GAS PRESSURE).
 - BOILERS OPERATE AND MODULATE BURNERS TO MAINTAIN HOT WATER SUPPLY TEMPERATURE. BOILER SHALL AUTOMATICALLY FIRE AS MANY STAGES OF HEATING AS NECESSARY TO MEET HEATING DEMAND.
 - BOILERS OPERATE IN CASCADING CONFIGURATION TO PROVIDE EVEN OPERATING HOURS.
 - IF A BOILER FAILS, SHUTDOWN ASSOCIATED BOILER PUMP AND DISABLE CASCADING MODE.
 - BOILER PUMPS (BP-1, BP-2)
 - BOILER PUMPS SHALL RUN ANYTIME THE BOILERS ARE CALLED TO RUN.
 - THE BOILER PUMPS SHALL START PRIOR TO THE BOILERS BEING ENABLED AND SHALL STOP ONLY AFTER THE BOILERS ARE DISABLED. DELAY ON START AND DELAY ON STOP SHALL BE ADJUSTABLE.
 - IF A BOILER PUMP FAILS, SHUTDOWN ASSOCIATED BOILER AND DISABLE CASCADING MODE.
 - MODULATE THE BOILER PUMP SPEED AS HEATING DEMAND VARIES.
 - HEATING WATER PUMPS (HWP-1, HWP-2)
 - ON A CALL FOR HEAT, LEAD HEATING WATER PUMP IS AUTOMATICALLY STARTED.
 - VFD SHALL MODULATE PUMP SPEED BASED ON FEEDBACK FROM DIFFERENTIAL PRESSURE TRANSMITTER TO MAINTAIN CONSTANT DIFFERENTIAL PRESSURE.
 - IF FLOW FROM LEAD HEATING WATER PUMP IS NOT SUFFICIENT, LAG SECONDARY PUMP IS STARTED, AND BOTH PUMPS MODULATE IN UNISON TO MAINTAIN DIFFERENTIAL SETPOINT.
 - BAS SHALL AUTOMATICALLY ROTATE LEAD HEATING WATER PUMP ON A WEEKLY BASIS (ADJ.)
 - RESET SYSTEM DIFFERENTIAL PRESSURE IN RESPONSE TO SYSTEM FLOWRATE.
 - HEATING WATER SUPPLY TEMPERATURE
 - THE HEATING WATER SUPPLY TEMPERATURE SETPOINT SHALL BE RESET USING A TRIM AND RESPOND ALGORITHM IN RESPONSE TO THE BUILDING'S HEATING DEMANDS TO REDUCE HEATING ENERGY USE.
 - THE HEATING WATER SUPPLY TEMPERATURE SETPOINT SHALL BE RESET BASED ON OUTDOOR AIR TEMPERATURE.
 - MINIMUM FLOW
 - THE BOILER PUMPS SHALL NOT TURNDOWN LESS THAN MINIMUM BOILER FLOW (15 GPM, ADJ.) SEE BOILER SCHEDULE.
 - SAFETY AND ALARMS
 - IF THE BOILER EXPERIENCES A FAULT CONDITION, SHUT DOWN THE BOILER AND PUMPS, AND GENERATE AN ALARM NOTIFICATION.
 - THE BOILER SHALL INCLUDE A FACTORY MOUNTED FLOW SWITCH TO MONITOR PROOF OF FLOW FOR EQUIPMENT START AND LOSS OF FLOW / LOW FLOW FOR EQUIPMENT SHUTOFF.
 - SYSTEM SHUTDOWN
 - IF THERE IS NO BUILDING HEATING DEMAND FOR MORE THAN AN ADJUSTABLE PROGRAMMED TIME LIMIT (15 MIN, ADJ.), SHUTDOWN THE BOILER AND PUMPS.
 - ALARMS:
 - BOILER FAILURE
 - BOILER PUMP FAILURE
 - HEATING WATER PUMP FAILURE
 - HIGH / LOW SUPPLY WATER TEMPERATURE
 - HIGH / LOW DIFFERENTIAL PRESSURE
 - LOW FLOW (FLOW SWITCH)
 - GRAPHIC DISPLAY:
 - OUTDOOR AIR TEMPERATURE
 - DIFFERENTIAL SYSTEM PRESSURE
 - DIFFERENTIAL SYSTEM PRESSURE SETPOINT
 - HEATING WATER RETURN TEMPERATURE
 - HEATING WATER SUPPLY TEMPERATURE
 - HEATING WATER SUPPLY TEMPERATURE SETPOINT
 - BOILER STATUS
 - BOILER PUMP STATUS
 - BOILER PUMP SPEED
 - HEATING WATER PUMP STATUS
 - HEATING WATER PUMP SPEED
 - OPERATING HOURS
 - TREND LOGS
 - ALARM HISTORY

ENERGY METERING

- ENERGY METERING - SEQUENCE OF OPERATION & BAS INTERFACE
- ENERGY METERING SHALL COMPLY WITH REQUIREMENTS OF ASHRAE 90.1 SECTION 8.4.3.
 - ELECTRICAL CONTRACTOR SHALL PROVIDE REMOTE METERING CAPABILITY.
 - MONITOR THE ELECTRICAL ENERGY USE FOR EACH OF THE FOLLOWING SEPARATELY:
 - TOTAL ELECTRICAL ENERGY
 - HVAC SYSTEMS
 - INTERIOR LIGHTING
 - EXTERIOR LIGHTING
 - RECEPTACLE CIRCUITS
 - THE ELECTRICAL ENERGY USE FOR ALL LOADS SPECIFIED ABOVE SHALL BE RECORDED A MINIMUM OF EVERY 15 MINUTES AND REPORTED HOURLY, DAILY, MONTHLY, AND ANNUALLY.
 - ENERGY USE DATA AS SPECIFIED ABOVE SHALL BE TRANSMITTED TO THE BAS AND GRAPHICALLY DISPLAYED.
 - DATA SHALL BE MAINTAINED FOR A MINIMUM OF 36 MONTHS.

OUTDOOR AIR SENSOR

- OUTSIDE AIR TEMPERATURE AND HUMIDITY - SEQUENCE OF OPERATION & BAS INTERFACE
- PROVIDE OUTSIDE AIR TEMPERATURE SENSOR AND OUTSIDE AIR HUMIDITY SENSOR. MOUNT ON NORTH WALL OF BUILDING.
 - BAS SHALL MONITOR OUTSIDE AIR TEMPERATURE AND HUMIDITY.
 - OUTSIDE AIR CONDITIONS SHALL BE VISIBLE ON THE GRAPHICAL USER INTERFACE, AND TRENDED FOR DIAGNOSTIC PURPOSES.

ELECTRIC HEATERS

- ELECTRIC HEATERS - SEQUENCE OF OPERATION & BAS INTERFACE**
- ELECTRIC HEATERS OPERATE VIA A FACTORY BUILT-IN THERMOSTAT. HEATER SHALL MODULATE TO MEET SPACE TEMPERATURE SETPOINT.
 - INITIAL SETPOINT: 60 DEG F (ADJUSTABLE).
 - EACH SPACE THAT HAS A HEATER WILL BE EQUIPPED WITH ADDITIONAL BAS CONNECTED SPACE TEMPERATURE SENSOR WHICH WILL GENERATE LOW SPACE TEMPERATURE ALERTS.
 - ALARMS: AT A MINIMUM, PROVIDE LOW SPACE TEMPERATURE.

CHILLED WATER SYSTEM


- CHILLED WATER SYSTEM CONTROL SEQUENCE (CH-1, CHP-1, CHP-2):
- AIR-COOLED CHILLER INCORPORATES INTEGRAL TEMPERATURE AND SAFETY CONTROLS. DDC SYSTEM INTERFACES TO CHILLER THROUGH BACNET NETWORK.
 - CHILLER (CH-1)
 - THE CHILLER SHALL BE ENABLED WHENEVER:
 - A PERCENTAGE OF ZONES CALL FOR COOLING (20%, ADJ.)
 - AND THE OUTSIDE AIR TEMPERATURE IS GREATER THAN 54F (ADJ.)
 - THE CHILLER SHALL RUN FOR AND BE OFF FOR MINIMUM ADJUSTABLE TIMES TO PREVENT SHORT CYCLING, UNLESS SHUTDOWN ON SAFETIES OR OUTSIDE AIR CONDITIONS.
 - THE CHILLER SHALL BE ENABLED A USER ADJUSTABLE TIME AFTER PUMP STATUS IS PROVEN ON. DELAY ON START SHALL BE ADJUSTABLE.
 - CHILLER OPERATES AND MODULATES COMPRESSORS TO MAINTAIN CHILLED WATER SUPPLY TEMPERATURE.
 - CHILLED WATER PUMPS (CHP-1, CHP-2)
 - CHILLED WATER PUMP SHALL RUN ANYTIME THE CHILLER IS CALLED TO RUN. CHILLED WATER PUMP SHALL ALSO RUN FOR FREEZE PROTECTION WHENEVER THE OUTSIDE AIR TEMPERATURE IS LESS THAN A USER DEFINABLE SETPOINT.
 - THE CHILLED WATER PUMP SHALL START PRIOR TO THE CHILLER BEING ENABLED AND SHALL STOP ONLY AFTER THE CHILLER IS DISABLED. DELAY ON START AND DELAY ON STOP SHALL BE ADJUSTABLE.
 - CHILLED WATER PUMPS OPERATE IN A LEAD / LAG CONFIGURATION. WHEN CHILLED WATER SYSTEM IS ON, ONE PUMP IS REQUIRED TO OPERATE. START PUMP WITH LOWEST RUNTIME (UNLESS IT HAS FAILED) OR HAS BEEN DESIGNATED OUT OF SERVICE, AND ROTATE PUMPS ON A WEEKLY BASIS.
 - IF OPERATING PUMP FAILS, IMMEDIATELY START BACKUP PUMP.
 - MODULATE THE CHILLED WATER PUMP SPEED TO MAINTAIN A DIFFERENTIAL PRESSURE SETPOINT (ADJ.) IN THE CHILLED WATER LOOP. FINAL SETPOINT DETERMINED DURING TAB.
 - CHILLED WATER SUPPLY TEMPERATURE
 - THE CHILLED WATER SUPPLY TEMPERATURE SETPOINT SHALL RESET USING A TRIM AND RESPOND ALGORITHM IN RESPONSE TO THE BUILDING'S COOLING DEMANDS TO REDUCE COOLING ENERGY USE.
 - MINIMUM FLOW
 - THE BAS SHALL MONITOR DIFFERENTIAL PRESSURE BETWEEN ENTERING AND LEAVING CHILLED WATER AT THE CHILLER EVAPORATOR AND SHALL MAINTAIN A MINIMUM PRESSURE DROP ACROSS THE CHILLER EVAPORATOR CORRESPONDING TO MINIMUM FLOW WHEN THE CHILLED WATER PUMP IS ENABLED AND THE CHILLER IS ENABLED.
 - THE MINIMUM PRESSURE DROP SHALL CORRESPOND TO CHILLER MANUFACTURER'S SPECIFIED MINIMUM CHILLED WATER FLOW AND SHALL BE MAINTAINED BY THE CHILLED WATER SYSTEM LOW FLOW BYPASS CONTROL VALVE INSTALLED IN THE FIELD PIPING.
 - DURING LOW FLOW OPERATIONS WITH CHILLER ENABLED, THE BYPASS CONTROL VALVE SHALL MODULATE OPEN TO MAINTAIN MINIMUM CHILLED WATER FLOW REQUIREMENTS AT CHILLER EVAPORATOR.
 - SAFETY AND ALARMS
 - IF THE CHILLER EXPERIENCES A FAULT CONDITION, SHUT DOWN THE CHILLER AND GENERATE AN ALARM NOTIFICATION.
 - IF THE CHILLED WATER PUMP FAILS TO MAINTAIN FLOW, INITIATE A BACKUP PUMP AND GENERATE AN ALARM NOTIFICATION.
 - THE CHILLER SHALL INCLUDE A FACTORY MOUNTED FLOW SWITCH TO MONITOR PROOF OF FLOW FOR EQUIPMENT START AND LOSS OF FLOW / LOW FLOW FOR EQUIPMENT SHUTOFF.
 - SYSTEM SHUTDOWN
 - IF THERE IS NO BUILDING COOLING DEMAND FOR MORE THAN AN ADJUSTABLE PROGRAMMED TIME LIMIT (15 MIN, ADJ.), SHUTDOWN THE CHILLER AND CHILLED WATER PUMP.
 - ALARMS:
 - CHILLER FAILURE
 - PUMP FAILURE
 - HIGH / LOW SUPPLY WATER TEMPERATURE
 - HIGH / LOW SYSTEM PRESSURE
 - LOW FLOW (FLOW SWITCH)
 - GRAPHIC DISPLAY:
 - OUTDOOR AIR TEMPERATURE
 - DIFFERENTIAL PRESSURE ACROSS CHILLER EVAPORATOR
 - DIFFERENTIAL PRESSURE ACROSS SUPPLY AND RETURN PIPING
 - CHILLED WATER RETURN TEMPERATURE
 - CHILLED WATER SUPPLY TEMPERATURE
 - CHILLED WATER SUPPLY TEMPERATURE SETPOINT
 - CHILLER KW
 - OPERATING HOURS
 - CHILLED WATER FLOW STATUS
 - CHILLED WATER PUMP STATUS
 - CHILLED WATER PUMP SPEED
 - CHILLER STATUS
 - TREND LOGS
 - ALARM HISTORY

FAN COIL UNITS

- FAN COIL UNITS - SEQUENCE OF OPERATION & BAS INTERFACE
- GENERAL: CONSTANT VOLUME FOUR-PIPE FAN COIL UNIT WITH VENTILATION AIR PROVIDED BY DOAS UNIT.
- FAN COIL UNITS WILL BE PROVIDED WITH FIELD CONTROLS BY CONTROLS CONTRACTOR TO CONTROL ALL FAN COIL UNIT COMPONENTS INCLUDING FANS AND COIL CONTROL VALVES. PROVIDE A COMPLETE SYSTEM TO CONTROL ALL UNIT FUNCTIONS INCLUDING TEMPERATURE CONTROL, SCHEDULING, MONITORING, UNIT SAFETY PROTECTION, AND DIAGNOSTICS. THE SYSTEM SHALL CONSIST OF ALL REQUIRED SENSORS AND CONTROLLERS.
 - EACH FAN COIL UNIT IS PROVIDED WITH AN ELECTRONIC ZONE THERMOSTAT.
 - THE BUILDING AUTOMATION SYSTEM (BAS) WILL SEND OCCUPIED, UNOCCUPIED, OPTIMAL START, NIGHT HEAT / COOL AND TIMED OVERRIDE COMMANDS. THE BAS WILL SEND DISCHARGE AIR TEMPERATURE SETPOINT.
 - OCCUPIED:**
DURING OCCUPIED PERIODS THE SUPPLY FAN WILL RUN CONTINUOUSLY.
 - COOLING:** 75 DEG F ZONE SETPOINT (ADJ.)
 - WHEN THE UNIT IS IN COOLING MODE, CHILLED WATER CONTROL VALVE MODULATES TO MAINTAIN DISCHARGE AIR TEMPERATURE SETPOINT TO MAINTAIN ZONE SETPOINT.
 - HEATING:** 70 DEG F ZONE SETPOINT (ADJ.)
 - WHEN THE UNIT IS IN HEATING MODE, HEATING WATER CONTROL VALVE MODULATES TO MAINTAIN DISCHARGE AIR TEMPERATURE SETPOINT TO MAINTAIN ZONE SETPOINT.
 - UNOCCUPIED (NIGHT SETBACK):**
FAN COIL UNIT CYCLES ON AND OFF, AND HEATING AND COOLING CONTROL VALVES ARE MODULATED, TO MAINTAIN UNOCCUPIED SETPOINTS (60 DEG F HEATING, 85 DEG F COOLING).
 - ALARMS:**
AT A MINIMUM, PROVIDE FAN FAILURE, CONDENSATE OVERFLOW.
 - UNIT STATUS:**
AT A MINIMUM, PROVIDE STATUS OF UNIT MODE, DISCHARGE AIR TEMPERATURE, CONTROL VALVE POSITION.

SPLIT SYSTEMS - AIR SOURCE

- SPLIT SYSTEMS - SEQUENCE OF OPERATION & BAS INTERFACE
- DUCTLESS WALL MOUNT FAN COILS OPERATE VIA A FACTORY WALL MOUNT THERMOSTAT PROVIDED BY THE MANUFACTURER TO MAINTAIN SPACE TEMPERATURE IN THE ASSOCIATED AREA. EQUIPMENT OPERATION IS BY LOCAL FACTORY CONTROLLER, CONNECTION TO BAS FOR MONITORING ONLY.
 - FAN COIL CYCLES FAN AND COOLING ON AND OFF UPON CALL FOR COOLING. OUTDOOR UNIT MODULATES COMPRESSOR TO MEET COOLING DEMAND. UNIT IS DISABLED WHEN SPACE TEMPERATURE IS SATISFIED.
 - WALL MOUNT THERMOSTAT SHALL BE MONITORED BY THE BAS.
 - INITIAL SETPOINT: 78 DEG F (ADJUSTABLE).
 - EACH SPACE THAT HAS A FAN COIL WILL BE EQUIPPED WITH ADDITIONAL BAS CONNECTED SPACE TEMPERATURE SENSOR WHICH WILL GENERATE HIGH OR LOW SPACE TEMPERATURE ALERTS.
 - ALARMS: AT A MINIMUM, PROVIDE HIGH SPACE TEMPERATURE, LOW SPACE TEMPERATURE, FAN COIL FAILURE, OUTDOOR UNIT FAILURE.
 - STATUS: AT A MINIMUM, PROVIDE STATUS OF UNIT MODE AND SPACE TEMPERATURE.



3
M703

SNOWMELT SYSTEM SLAB INSTALLATION
NTS

